

DRAFT - DISCHARGE UPDATE REPORT

Project: Temple-Inland Bogalusa Mill
Project Location: Bogalusa, Louisiana
Report Prepared By: Meredith Raetz
Date: September 15, 2011
Status of Report: Complete as of 9:00 on September 16, 2011

Weather Conditions: AM: fair/ cloudy PM: fair/ cloudy
Temperature: Max. 87°F
Cloud Cover: (No)
Precipitation: (No)

Discharge:
Beginning Time: Continuous
Ending Time:
Discharge Stoppage: No

Reason for Stoppage:
Description:

Activities, Remarks:

- Outfall monitoring was conducted in accordance with approved plan.
- Discharging through west, east, and middle gates.
- pH of discharge was within acceptable range.
- ASB microbiology looks good with many higher life forms. Rotifers were seen at the weir samples indicating good BOD removal. Ammonia residuals were sufficient and nutrient was gravity fed for 1 hour and 45 minutes. Continue bacteria addition at 100lbs/day.

Problems/Deficiencies/Corrective Actions:

- None

Samples Taken / Results:

- Samples collected per frequencies indicated in Table 1 of approved Discharge Plan and results (to time indicated in above status) presented in attached table.

Calibration Records on Field Testing Equipment

- EBS sampling meters calibrated prior to start of discharge

Oversight/Visitors

- LDEQ representatives on site
- EBS Sampling Laboratory